

**Evaluation of false alarm rates of a walkthrough detection portal designed for detecting triacetone triperoxide (TATP) vapour from field test results and receiver operating characteristic (ROC) curves**

Takada Y, Nagano H, Kawaguchi Y, Suzuki Y, Nakajima E, Sugiyama M, Sugaya M, Hashimoto Y, Sakairi M.

International journal of safety and security engineering  
2012; 2(3):256-264

**ARTICLE IDENTIFIERS**

DOI: 10.2495/SAFE-V2-N3-256-264

PMID: unavailable

PMCID: not available

**JOURNAL IDENTIFIERS**

LCCN: not available

pISSN: 2041-9031

eISSN: 2041-904X

OCLC ID: 751782434

CONS ID: not available

US National Library of Medicine ID: not available

This article was identified from a query of the SafetyLit database.